

Yuima Municipal Water District

2013 Consumer Confidence Report

Annual Report on Water Quality for 2013

Dated: June 1, 2014

We test the quality of your drinking water for many constituents as required by State and Federal regulations. This report shows the results of our monitoring for the period of January 1 – December 31, 2013.

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo o hable con alguien que lo entienda bien.

Since 1990, all water utilities in the State of California have been required to distribute to all customers an annual Consumer Confidence Report that provides information regarding the quality of water they served. In 1996, Congress amended the Safe Drinking Water Act and added a similar requirement for a brief annual water quality report.

This report, the *2013 Consumer Confidence Report* (CCR) is more specific and detailed in content. The California Department of Public Health (CDPH), in order to implement state and national policy, oversees the issuance of this report. Yuima Municipal Water District (Yuima or District) is a community water system providing the public water supply that serves much of the community of Pauma Valley. The following report provides information to Yuima's customers regarding test results available through December 31, 2013.

To receive more information about your water, to ask questions, or to receive additional copies of this report, please call Yuima's General Manager, Linden A. Burzell at (760) 742-3704. Written questions should be addressed to the General Manager at P.O. Box 177, Pauma Valley, CA 92061.

Board of Directors Meetings

Regular meetings of the Board of Directors are generally held monthly on the fourth Monday at 2:00 pm at the District office at 34928 Valley Center Road, Pauma Valley. Each monthly agenda has a scheduled time for public comments during the meeting and is posted at the District Office and is available on the District website.

Board of Directors

W.D. "Bill" Knutson, President
Ron W. Watkins, Vice President
George Stockton, Secretary/Treasurer
Michael D. Fitzsimmons, Director
Douglas K. Anderson, Director

Staff

Linden A. Burzell, Ph.D., General Manager
Lori A. Johnson, Director of Finance
Todd Engstrand, P.E., Director of Operations,
Maintenance and Engineering
Jeffrey G. Scott, General Counsel

This report explains:

- ◆ *Where your water comes from*
- ◆ *How water quality is evaluated*
- ◆ *Regulations that protect your health*
- ◆ *How your drinking water measures up against State and Federal drinking water standards for safety, appearance, taste and odor, and*
- ◆ *Where to go if you have questions*

Where your water comes from: Yuima relies on two main sources: local groundwater and imported surface water. The water quality issues that affect groundwater and imported surface water are somewhat different.

Local groundwater is pumped from deep underground wells located throughout Pauma Valley. This underground aquifer is known as the Pauma Groundwater Basin. Yuima doses a sodium hypochlorite solution (chlorine) to treat and disinfect its well water to remove potential bacteria contamination found naturally in the environment.

The District is not required to do any further treatment. Other agencies that use surface source water must provide additional treatment. Surface water by definition is water from lakes and streams usually impounded in open reservoirs where the water is subject to the pollutants in the watershed of its origin.

Imported water is purchased by Yuima from the San Diego County Water Authority, which in turn purchases the majority of its imported water from Metropolitan Water District of Southern California (Metropolitan). Metropolitan imports water into Southern California from two sources: a 242 mile-long aqueduct that brings water from the Colorado River's Lake Havasu, and a 444 mile-long aqueduct that carries water from the Sacramento-San Joaquin River Delta (State Project). Water from these sources is conveyed to the Metropolitan system through pressurized large diameter pipes, open aqueduct canals and open reservoirs. The supply is then treated at the Robert F. Skinner Filtration Plant located in western Riverside County.

These imported surface water sources are potentially vulnerable to contamination. Metropolitan has determined that the Colorado River supplies are most vulnerable due to recreation, urban/storm water runoff,

increasing urbanization in the watershed and wastewater. State Project water supplies are considered most vulnerable due to urban/storm water runoff, wildlife, agriculture, recreation and wastewater. A copy of Metropolitan's assessment of these vulnerabilities can be obtained through contacting Metropolitan by phone at (213) 217-7426.

How Water Quality is Evaluated: Water quality is evaluated by performing periodic laboratory analyses on water samples to determine the physical characteristics of the water and the presence or absence of chemical, biological and radiological contaminants. Contaminants that may be present in source water include:

- ◆ *Microbial contaminants*, such as viruses and bacteria that may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.
- ◆ *Inorganic contaminants*, such as salts and metals, which can be naturally occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
- ◆ *Pesticides and herbicides*, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- ◆ *Organic chemical contaminants*, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, agricultural operations, urban storm water runoff and septic systems.
- ◆ *Radioactive contaminants*, which can be naturally occurring or present as a result of contamination from mining and/or other activities.

Additional Information on Drinking Water

All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of trace amounts of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as those undergoing chemotherapy, organ transplant recipients, and those with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk. These people should seek advice about drinking water from their health care providers.

The USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

ABBREVIATIONS USED IN THIS REPORT

- ◆ **PDWS = "Primary Drinking Water Standards"** The highest level of a contaminant that is allowed in drinking water. Primary MCL's are set as close to the PHG's (or MCLG's) as is economically and technologically feasible. Secondary MCL's are set to protect the odor, taste, and appearance of drinking water.
- ◆ **SDWS = "Secondary Drinking Water Standards"** Limits established by regulation that set the maximum amount of specific contaminants that affect the taste, odor, or appearance of the drinking water.
- ◆ **PHG = "Public Health Goal"** The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.
- ◆ **MCLG = "Maximum Contaminant Level Goal"** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency.
- ◆ **MCL = "Maximum Contaminant Level"** The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.
- ◆ **MRDL = "Maximum Residual Disinfectant Level"** The level of a disinfectant added for water treatment that may not be exceeded at the consumer's tap.
- ◆ **MRDLG = "Maximum Residual Disinfectant Level Goal"** The level of a disinfectant added for water treatment below which there is no known or expected risk to health. MRDLG's are set by the U.S. Environmental Protection Agency.
- ◆ **RAL = "Regulatory Action Level"** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.
- ◆ **N/A** = not applicable.
- ◆ **NC** = not collected.
- ◆ **ND** = not detectable at testing limit.
- ◆ **NTU** = Nephelometric Turbidity Units, a measure of the suspended material in water.
- ◆ **ppb** = parts per billion.
- ◆ **µg/l** = micrograms per liter.
- ◆ **ppm** = parts per million or milligrams per liter.
- ◆ **pCi/l** = picocuries per liter (a measure of radiation).
- ◆ **CFU/100 ml** = colony forming units per 100 milliliters.
- ◆ **µmho/cm** = micromhos per centimeter; a measure of electrical conductivity.
- ◆ **TT = "Treatment Technique"** A required process intended to reduce the level of a contaminant in drinking water.

Additional Notes

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material and can pick up substances resulting from the presence of animals or from human activity.

In order to ensure that tap water is safe to drink, USEPA and the CDPH have issued regulations that limit the amount of certain contaminants in water provided by public water systems. CDPH regulations also establish limits for contaminants in bottled water that must provide the same protection for public health. A *Source Water Assessment* was conducted for the Yuima Municipal Water District system in 2010 and updated in 2012.

Nitrate: Nitrate in drinking water at levels above 45 mg/L is a health risk for infants of less than six months of age. Such nitrate levels in drinking water can interfere with the capacity of the infant’s blood to carry oxygen, resulting in a serious illness; symptoms include shortness of breath and blueness of the skin. Nitrate levels above 45 mg/L may also affect the ability of the blood to carry oxygen in other individuals, such as pregnant women and those with certain specific enzyme deficiencies. If you are caring for an infant, or you are pregnant, you should seek advice from your health care provider. Nitrate levels may rise quickly for short periods of time because of rainfall or agricultural activity. Nitrate is found in all District wells at varying levels but is blended down below 45 mg/L before it is supplied to District customers.

Perchlorate: At high levels, Perchlorate has been shown to interfere with thyroid function by reducing iodine uptake by the thyroid gland, thereby reducing the production of thyroid hormones and leading to adverse effects associated with hyper-thyroidism, particularly in the developing fetus, infants and young children. The effects of perchlorate on thyroid function are dose-dependent and reversible.

Perchlorate has been detected at low levels in certain District wells, most likely as a result of heavy applications of fertilizers over a period of many years by commercial agriculture on overlying lands. Though present at levels well below those associated with adverse health effects in humans, the perchlorate concentration is further reduced by blending with perchlorate-free water from other sources before delivery to any of the District’s customers.

Lead: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Yuima Municipal Water District is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Discussion of Vulnerability – Although no contaminants other than nitrates and perchlorates have been detected in the local water supply, the system is still considered vulnerable to activities carried out near the drinking water sources. The most significant identified sources of possible contamination are fertilizer and pesticide use from agriculture groves in the area surrounding District wells. All drinking water sources in Yuima Municipal Water District are secured from vandalism by locked entrance gates and fencing with barbed wire.

Lead and Copper (testing done June 2011)	No. of samples collected	90 th percentile level detected	No. sites exceeding RAL	RAL	PHG	Typical Source of Contaminant
Lead (ppb) Yuima IDA	5 5	1 6	0	15	0.2	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits
Copper (ppm) Yuima IDA	5 5	0.24 0.56	0	1.3	0.3	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

2013 Consumer Confidence Report - Yuima Municipal Water District

Parameter	Units	State or Federal MCL [MRDL]	PHG (MCLG) [MRDLG]	State DLR	Range Average	Testing Date Range	Combined Sources Yuima/IDA	Imported Colorado State Project	Major Sources in Drinking Water
PRIMARY STANDARDS--Mandatory Health-Related Standards									
MICROBIOLOGICAL									
Total Coliform					Range	2013	ND	ND-0.2	
Bacteria	%	5.0	(o)	NA	Average		ND	ND	Naturally present in the environment
ORGANIC CHEMICALS - none to report									
<i>Semi-Volatile Organic Compounds- none to report</i>									
<i>Volatile Organic Compounds</i>									
Trichlorofluoromethane (Freon-11)	ppb	150	700	5	Range	2013	ND-57	ND	Industrial factory discharge; degreasing solvent; propellant
					Average		21.4	ND	
INORGANIC CHEMICALS									
Aluminum	ppb	1000	600	50	Range	2013	ND-67	ND - 360	Residue from water treatment process; natural deposits erosion
					Average		6.3	134	
Barium	ppb	1000	2000	100	Range	2013	1.4-140	ND	Oil and metal refineries discharges; natural deposits erosion
					Average		74.1	ND	
Chromium	ppb	50	(100)	10	Range	2013	ND-2	ND	Discharge from steel and pulp mills; natural deposits erosion
					Average		0.1	ND	
Copper	ppm	AL = 1.3	0.3	0.05	Range	2013	ND-0.012	ND	Internal corrosion of household pipes; natural deposits erosion
					Average		0.0052	ND	
Fluoride	ppm	2.0	1	0.1	Range	2013	0.2-0.3	0.7-1	Erosion of natural deposits; water additive that promotes strong teeth
					Average		0.21	0.8	
Lead	ppb	AL = 15	0.2	5	Range	2013	ND-2.8	ND	House pipes internal corrosion; erosion of natural deposits
					Average		0.26	ND	
Nickel	ppb	100	12	10	Range	2013	ND-2.5	ND	Erosion of natural deposits; discharge from metal factories
					Average		0.14	ND	
Nitrate (as NO3) MWD	ppm	45	45	2	Range	2013	NA	ND-5	Runoff and leaching from fertilizer use; septic tank and sewage; natural deposits erosion
					Average		NA	2.3-10.2	
Nitrate (as NO3) Yuima	ppm	45	45	2	Range	2013	ND-44	NA	Runoff and leaching from fertilizer use; septic tank and sewage; natural deposits erosion
					Average		27	NA	
Perchlorate	ppb	6	6	4	Range	2013	<4-6.8	ND	Industrial waste discharge
					Average		<4	ND	
Selenium	ppb	50	30	5	Range	2013	ND-9.1	ND	Refineries, mines, and chemical waste discharge; runoff from livestock lots
					Average		3.4	ND	
RADIOLOGICALS									
Gross Alpha Particle Activity	pCi/L	15	(0)	3	Range	2013	ND-5.8	ND-3	
					Average		ND	0.6	Erosion of natural deposits
Gross Beta Particle Activity	pCi/L	50	(0)	4	Range	2013	3.3	ND-6	
					Average		3.3	0.8	Decay of natural and man-made deposits
Radium-226	pCi/L	NA	0.05	1	Range	2013	ND-0.1	ND	
					Average		ND	ND	Erosion of natural deposits
Radium-228	pCi/L	NA	0.019	1	Range	2013	ND-0.4	ND	
					Average		ND	ND	Erosion of natural deposits
Uranium	pCi/L	20	0.43	1	Range	2013	ND-7.7	ND-2	
					Average		ND	1.4	Erosion of natural deposits
DISINFECTION BY-PRODUCTS, DISINFECTANT RESIDUAL, AND DISINFECTION BY-PRODUCTS PRECURSORS									
Total Trihalomethanes (TTHM)	ppb	80	NA	1	Range	2013	12-32	9.1-55	
					Average		22	27	By-product of drinking water chlorination
Haloacetic Acids (HAA5)	ppb	60	NA	1	Range	2013	9-11	1.2-21	
					Average		10	10.4	By-product of drinking water chlorination
Total Chlorine Residual	ppm	[4.0]	[4.0]	NA	Range	2013	ND-2.2	ND-2.9	
					Average		1.3	2.3	Drinking water disinfectant added for treatment

2013 Consumer Confidence Report - Yuima Municipal Water District

Parameter	Units	State or Federal MCL [MRDL]	PHG (MCLG) [MRDLG]	State DLR	Range Average	Testing Date Range	Combined Sources Yuima/IDA	Imported Colorado State Project	Major Sources in Drinking Water
SECONDARY STANDARDS--Aesthetic Standards									
Aluminum	ppb	200	NA	50	Range Average	2013	ND-67 6.3	ND-360 134	Residue from water treatment process; natural deposits erosion
Chloride	ppm	500	NA	NA	Range Average	2013	9.2-130 74.2	75-100 84.8	Runoff/leaching from natural deposits; seawater influence
Color	Units	15	NA	NA	Range Average	2013	ND-50 3.6	1.2 1.6	Naturally occurring organic materials
Iron	ppb	300	NA	100	Range Average	2013	ND-440 ND	ND ND	Leaching from natural deposits; industrial wastes
Manganese	ppb	50	NL = 500	20	Range Average	2013	ND-74 ND	ND ND	Leaching from natural deposits
Odor Threshold	TON	3	NA	1	Range Average	2013	ND-4 0.4	2-6 3	Naturally-occurring organic materials
Specific Conductance	µS/cm	1600	NA	NA	Range Average	2013	330-1200 800	520-900 744	Substances that form ions in water; seawater influence
Sulfate	ppm	500	NA	0.5	Range Average	2013	67-270 144.3	44-200 128.4	Runoff/leaching from natural deposits; industrial wastes
Total Dissolved Solids (TDS)	ppm	1000	NA	NA	Range Average	2013	270-990 578.4	280-560 436	Runoff/leaching from natural deposits; seawater influence
Turbidity	NTU	5	NA	NA	Range Average	2013	ND-18 1.4	ND ND	Soil runoff
Zinc	ppm	5.0	NA	0.05	Range Average	2013	ND-100 13.6	ND ND	Runoff/leaching from natural deposits; industrial wastes
FEDERAL UNREGULATED CHEMICALS REQUIRING MONITORING (UCMR2)									
OTHER PARAMETERS									
MICROBIOLOGICAL									
HPC (d)	CFU/mL	TT	NA	NA	Range Median	2013	NA NA	ND-1 ND	Human and animal fecal waste
CHEMICAL									
Alkalinity	ppm	NA	NA	NA	Range Average	2013	136.7 20-120	63-130 19-61	
Calcium	ppm	NA	NA	NA	Range Average	2013	77 NA	44.8 25-62	By-product of drinking water chlorination; industrial processes
Chlorate	ppb	NL=800	NA	20	Range Average	2013	NA NA	28.72 11.9-12.5	Runoff/leaching from natural deposits; industrial wastes
Corrosivity (as Aggressiveness Index)	AI	NA	NA	NA	Range Average	2013	11-13 12	11.9-12.5 12.2	Elemental balance in water; affected by temperature, other factors
Hardness	ppm	NA	NA	NA	Range Average	2013	291.7 291.7	100-250 188	
Magnesium	ppm	NA	NA	NA	Range Average	2013	6.3-45 24.2	12-23 17.6	
pH	pH Units	NA	NA	NA	Range Average	2013	6.9-8.9 7.5	8.1-8.4 8.2	
Potassium	ppm	NA	NA	NA	Range Average	2013	0.6-8 5.2	2.6-4.4 3.6	
Sodium	ppm	NA	NA	NA	Range Average	2013	21-96 49.8	57-87 74.4	Salt present in the water and is generally naturally occurring

YUIMA MUNICIPAL WATER DISTRICT
P.O. Box 177
Pauma Valley, Ca. 92061
(760) 742-3704